

SUPERINTENDENT'S MONTHLY OPERATING REPORT WATER & WASTEWATER TREATMENT FEBRUARY 2010

Wastewater Treatment Plant

In addition to their routine duties, our Operators performed the following tasks:

- *The bathroom was cleaned and painted.
- *Detroit Air Compressor repaired the air compressor at the WWTP after the compressor kept tripping the breaker.
- *Ferric chloride tank was cleaned after a load of solid contaminated chemical was received. The several fed lines are plugged.
- *The mechanical seal on the 6" trash pump was replaced.
- *Pulled pump #2 at lift station #7 and removed rags. During one of the removals the guide rails for the pump pulled loose from the cement. Hydrodynamics, Inc. came and replaced the guides. Rags were also removed from one of the check valves.
- *Door handle was replaced at lift station #5.
- *Electrical line to sump pump in basement of WWTP was begun to be rerouted to the emergency circuit.

Water Treatment Plant

In addition to their routine duties, our Operators performed the following tasks:

- *Peerless-Midwest was here to perform annual preventative maintenance on the well and high service pumps.

Landfill

In addition to their routine duties, our Operators performed the following tasks:

- *Nothing significant

Administrative Functions

During the month, the following administrative tasks were performed:

- *The WWT Dept. hosted the Northern Lower Michigan Water Association meeting on Feb 10.
- *John Holland attended board training.
- *Final approval was given to place Well #9 online by the DNRE.
- *Bid proposals were reviewed for the WWTP expansion.
- *ISP antenna proposals were reviewed.
- *Stormwater monitoring plan was reviewed and a certificate of assurance was sent to the DNRE.
- *The Consumer Confidence Report Certificate of Publication was sent to the DNRE.

***Josh Miller and John Nabbefeld attended the MRWA lab class at the Ionia WWTP.**

* This is a Consent Agenda item and is considered as routine by the City Commission. As such, this matter shall be automatically enacted by one motion with all other Consent Agenda items unless a Commissioner or citizen requests this item be individually discussed, in which event it shall be removed from the Consent Agenda and considered and acted upon in its designated sequence on the approved Agenda of the Clare City Commission.